



# Certificate of Compliance

**Certificate:** 1108962 **Master Contract:** 176070  
**Project:** 80194066 **Date Issued:** 12/27/2023  
**Issued to:** Sato Parts Co., Ltd.  
3-3-8, Sotokanda  
Chiyoda-ku, Tokyo 101-0021  
Japan  
**Attention:** Yutaka Kodama

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Dino Du*  
Dino Du

## PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

**Terminal blocks for solid and stranded insulated copper conductors**

Models	Current (A)	Input Voltage (V)	Spacing Group	Wire Range (AWG)
Cat No ML-1400, Cat No. ML-1800	10	300	B, D and E	14-22 solid copper

## Notes:

1. Suffixes may be added to the above series designation to complete the catalogue number, to denote e.g. the number of circuits.
2. These terminal blocks are Certified only for supply to manufacturers for the assembly, as components, of Certified electrical equipment where the suitability of the combination is to be determined in the end use.

## APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



**Certificate:** 1108962

**Project:** 80194066


**Master Contract:** 176070

**Date Issued:** 12/27/2023

---

**Notes:**

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 1108962

**Master Contract:** 176070

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
80194066	December 27, 2023	Update report to remove materials 2015SE, 2015SV, AN60, update manufacturer name and file number for material LN60.
80115287	May 24, 2022	Update to Report 1108962 according to CSA wiring notice 77 (effective date: December 31, 2014) to reflect the latest requirements of new published standard CSA C22.2 No. 158-10.
2595377	January 24, 2013	Update to Report 1108962 to cover report correction of material designation from AN30SFN31 to A30SF31.
2573112	November 12, 2012	Update to Report 1108962 to cover alternate sectional block, end barrier and spacing piece material.
2194297	July 21, 2009	Update to Report 1108962 to cover alternative button material.
1439458	July 02, 2003	Update to Report 1108962 to add similar models half pitch staggered type to Series ML-1800.
1349490	August 08, 2002	Update to Report 1108962 to add alternate copper alloy wire terminal.
1108962	July 28, 2000	Report Conversion - Supersedes Report LR 65928-40 and update to alternate wire terminal. LR 65928-58 1999-08-25 Update to Report 1108962 to add alternate construction to Series ML-1400, provided with check terminal. LR 65928-57 1999-07-30 Update to Report 1108962 to add similar models, ML-1800 of two tiers type. LR 65928-43 1997-02-26 Update to Report 1108962 to add alternate markings on the carton. LR 65928-42 1996-10-24 Update to Report 1108962 to add low height wire release type, Cat Nos ML- MOOS IL and ML-1400S2L with suffixes. LR 65928-40 1996-02-21 Original Certification.
6592858	August 25, 1999	Update to Report 1108962 to add alternate construction to Series ML-1400, provided with check terminal.



**Certificate:** 1108962

**Master Contract:** 176070

**Project:** 80194066

**Date Issued:** 12/27/2023

---

6592857	July 30, 1999	Update to Report 1108962 to add similar models, ML-1800 of two tiers type.
6592843	February 26, 1997	Update to Report 1108962 to add alternate markings on the carton.
6592842	October 24, 1996	Update to Report 1108962 to add low height wire release type, Cat Nos ML- MOOS IL and ML-1400S2L with suffixes.
6592840	February 21, 1996	Original Certification.