



Certificate of Compliance

Certificate: 1180873 **Master Contract:** 176070
Project: 80194067 **Date Issued:** 12/27/2023
Issued to: Sato Parts Co., Ltd.
3-3-8, Sotokanda
Chiyoda-ku, Tokyo 101-0021
Japan
Attention: Yutaka Kodama

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Dino Du*
Dino Du

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Sectional terminal block assemblies, push-in type:

Models	Voltage (V)	Current (A)	Spacing Group	Wire Range (AWG)
ML-1600	300	7	B, D, E	18-26 solid copper, 20-24 stranded copper

Notes:

1. Suffixes may be added to the above series designation to complete the catalogue number, to denote e.g. the number of circuits.
2. These terminal blocks are Certified only for supply to manufacturers for the assembly, as components, of Certified electrical equipment where the suitability of the combination is to be determined in the end use.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 1180873


Project: 80194067

Master Contract: 176070

Date Issued: 12/27/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1180873

Master Contract: 176070

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80194067	December 27, 2023	Update report to remove materials 2015SE, 2015SV, AN60, update manufacturer name and file number for material LN60.
80115288	May 30, 2022	Update to Report 1180873 according to CSA wiring notice 77 (effective date: December 31, 2014) to reflect the latest requirements of new published standard CSA C22.2 No. 158-10.
2595378	January 24, 2013	Update to Report 1180873 to cover report correction of material designation from AN30SFN31 to A30SFN31.
2573113	November 16, 2012	Update to Report 1180873 to cover alternative materials used in sectional block and lockout cap.
2194302	July 21, 2009	Update to Report 1180873 for alternate body material, end barrier, spacing piece, lockout caps and button.
1407206	February 21, 2003	Update to Report 1180873 for expansion of applicable wire range.
1360153	September 25, 2002	Update to Report 1180873 for alternate sectional block.
1221705	July 10, 2001	Update to Report 1180873 for addition of alternate wire terminal.
1180873	February 28, 2001	Report Conversion - Supersedes Report LR 65928-44 and update to add optional spacing piece and lockout cap. LR 65928-44 1997-05-13 Original Certification.
6592844	May 13, 1997	Original Certification.