



Certificate of Compliance

Certificate: 1096584 **Master Contract:** 176070
Project: 80194074 **Date Issued:** 12/27/2023
Issued to: Sato Parts Co., Ltd.
3-3-8, Sotokanda
Chiyoda-ku, Tokyo 101-0021
Japan
Attention: Yutaka Kodama

The products listed below are eligible to bear the CSA Mark shown



Issued by: Dino Du
Dino Du

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, model series ML-1700, spring forced, sectional, for use with insulated, solid or stranded copper conductors, for rail mounting or surface mounting, rated as shown below:

Models	Current (A)	Wire Range (AWG)	Mounting	Voltage (V)	Spacing Group
ML-1700-A, ML-1700-B, ML-1700-C, ML-1700-D	10	26-16 AWG/ Solid, 22-16 AWG/ Stranded	Surface	300	B, D, E

Models	Current (A)	Wire Range (AWG)	Mounting	Voltage (V)	Spacing Group
ML-1700-E, ML-1700-F	10	26-16 AWG/ Solid, 22-16 AWG/ Stranded	Rail	300	B, D, E

Models	Current (A)	Wire Range (AWG)	Mounting	Voltage (V)	Spacing Group
ML-1700U	10	26-16 AWG/ Solid, 22-16 AWG/ Stranded	Surface/Rail	300	B, D, E

Notes: 1. Cat. No. may be followed by any number 1 through 100, and letter "P" for design options. 2. These terminal blocks are



Certificate: 1096584

Master Contract: 176070

Project: 80194074

Date Issued: 12/27/2023

supplied only to manufacturers, as components, for the assembly of Certified electrical equipment where the suitability of the combinations is determined by CSA. 3. ML-1700U is combination model for ML-1700-A and ML-1700-B, ML-1700-C and ML-1700-D, or ML-1700-E and ML-1700-F. Suffix "U" replaces 1 to 9 digit(s) number and/or letter(s) denoting a customer code.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 1096584


Project: 80194074

Master Contract: 176070

Date Issued: 12/27/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1096584

Master Contract: 176070

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80194074	December 27, 2023	Update report to remove materials 2015SE and 2015SV.
70204040	November 27, 2018	Addition of alternate End Barrier for model ML-1700 (Surface Mounting).
70140461	July 12, 2017	Addition of new models Cat. Nos. ML-1700-E and ML-1700-F. (CSA C22.2 No.158-10).
2573115	November 16, 2012	Alternate sectional block body, end barrier and mounting block material.
1096584	June 27, 2000	Original Certification. (Transferred from Report LR 65928-49 and update to include alternative construction to Model ML-1700.)