



Certificate of Compliance

Certificate: 1096584

Master Contract: 176070

Project: 70204040

Date Issued: 2018-11-27

Issued to: Sato Parts Co., Ltd.
3-42-1 Hongo
Bunkyo-ku, Tokyo, 113-0033
JAPAN

Attention: Mr. Yutaka Kodama

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Shota Inoue

PRODUCTS

CLASS NO 6228 01 – WIRECONNECTING DEVICES – Terminal Assemblies

Terminal blocks, model series ML-1700, spring forced, sectional, for use with insulated, solid or stranded copper conductors, for rail mounting or surface mounting, rated as shown below:

<u>Cat No</u>	<u>Mounting</u>	<u>Amp</u>	<u>Volts</u>	<u>Spacings Groups</u>	<u>Wire Range/ Type</u>
ML-1700-A	Surface	10A	300V	B, D, E	26-16 AWG/ Solid
ML-1700-B					22-16 AWG/ Stranded
ML-1700-C					
ML-1700-D					
ML-1700-E	Rail	10A	300V	B, D, E	26-16 AWG/ Solid
ML-1700-F					22-16 AWG/ Stranded
ML-1700U	Surface / Rail	10A	300V	B, D, E	26-16 AWG/ Solid 22-16 AWG/ Stranded



Certificate: 1096584

Master Contract: 176070

Project: 70204040

Date Issued: 2018-11-27

Notes:

1. Cat. No. may be followed by any number 1 through 100, and letter “P” for design options.
2. These terminal blocks are supplied only to manufacturers, as components, for the assembly of Certified electrical equipment where the suitability of the combinations is determined by the CSA International.
3. ML-1700U is combination model for ML-1700-A and ML-1700-B, ML-1700-C and ML-1700-D, or ML-1700-E and ML-1700-F. Suffix “U” replaces 1 to 9 digit(s) number and/or letter(s) denoting a customer code.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.158-10 - Terminal Blocks