



# Certificate of Compliance

**Certificate:** 1938346 **Master Contract:** 176070  
**Project:** 80199950 **Date Issued:** 2024-03-06  
**Issued to:** Sato Parts Co., Ltd.  
3-3-8, Sotokanda  
Chiyoda-ku, Tokyo 101-0021  
Japan  
**Attention:** Yutaka Kodama

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Dino Du*  
Dino Du

## **PRODUCTS**

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

**Terminal blocks, model series ML-30, screw type, 250V, 10A, tightening torque 0.5N-m, for use with solid or stranded copper conductor as shown below:**

Model(s)	Current (A)	Voltage (V)	Spacing Group	Wire Range (AWG)
ML-30	10	250	B, D, E	22-14 AWG/Solid (Suffix S or F) 22-14 AWG/Str. (Suffix S) 22-16 AWG/Str. (Suffix F) 24-14 AWG/Solid/Str. (Without suffix S or F)

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



**Certificate:** 1938346


**Project:** 80199950

**Master Contract:** 176070

**Date Issued:** 2024-03-06

**Notes:**

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 1938346

**Master Contract:** 176070

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80199950	2024-03-06	Update report to add alternate body material PM-9750 and add 4 illustrations for minor alternate construction for body.
80082708	2021-11-19	Add alternate body material PM 8425J by Sumitomo (E41429); update to Wiring Devices Notice No. 77- CSA Std 158-10.
1938346	2007-07-26	Change of body material manufacturer's name.
2500009426	2000-04-14	Add terminal block without "Y" suffix. -55 1999-4-08 Original Certification.