



# Certificate of Compliance

**Certificate:** 1792314

**Master Contract:** 176070

**Project:** 70019432

**Date Issued:** 2015/03/07

**Issued to:** Sato Parts Co., Ltd.  
3-3-3 Ebisu  
Shibuya-ku, Tokyo 150-0013  
JAPAN  
**Attention:** Mr. Yoshitaki Shigeno

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Shigeru Imano

## PRODUCTS

CLASS 6228 01– WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, model series ML-5100, screw-type, sectional, for use with insulated, stranded copper conductors, rated as shown below:

<u>Cat No</u>	<u>Amp</u>	<u>Volts</u>	<u>Spacings Groups</u>	<u>Wire Range/ Type</u>
ML-5100-M5	60	600	B & C	4 AWG/ Stranded
ML-5100-M6	75	600	B & C	3 AWG/ Stranded

### Notes:

1. These terminal blocks are supplied only to manufacturers, as components, for the assembly of Certified electrical equipment where the suitability of the combination is determined by the CSA International.
2. A suffix is added to denote number of poles ("1P" to "15P").

## APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 158-10 - Terminal Block