



Certificate of Compliance

Certificate: 1083851 **Master Contract:** 176070
Project: 80194072 **Date Issued:** 12/27/2023
Issued to: Sato Parts Co., Ltd.
3-3-8, Sotokanda
Chiyoda-ku, Tokyo 101-0021
Japan
Attention: Yutaka Kodama

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Dino Du*
Dino Du

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks

Models	Voltage (V)	Current (A)	Spacing Group	Wire Range (AWG)
ML-800	300	10	B, D, E	16-26 solid copper, 16-24 stranded copper

Notes:

1. Suffixes may be added to the above series designation to complete the catalogue number, to denote e.g. pitch of terminals, type of terminals and the number of circuits.
2. These are Certified only for supply to manufacturers for the assembly, as components, of Certified electrical equipment where the suitability of the combination is to be determined in the end use.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 1083851


Project: 80194072

Master Contract: 176070

Date Issued: 12/27/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1083851

Master Contract: 176070

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80194072	December 27, 2023	Update report to remove materials 2015SE, 2015SV, AN60, update manufacturer name and file number for material LN60.
80115285	April 20, 2022	Update to Report 1083851 according to CSA wiring notice 77 (effective date: December 31, 2014) to reflect the latest requirements of new published standard CSA C22.2 No. 158-10. Delisting of terminal block Series ML-810 per client request dated 10/12/2021. Classes: 6228 01.
2595374	January 24, 2013	Update to Report 1083851 to cover report correction of material designation from AN30SFN31 to A30SFN31.
2573109	November 16, 2012	Update to Report 1083851 to cover alternate housing, shield, spacing piece, mounting block and lockout cap materials.
2194296	July 21, 2009	Update to Report 1083851 to cover alternative button material.
1083851	May 02, 2000	Report Conversion - Supersedes Report LR 65928-21 and update for alternative use of housing material and wire terminal, addition of optional lockout cap and additional description of spacing piece. LR 65928-51 1998-09-28 Revised rating from 250V to 300V for Series ML-800, alternate button and terminal, addition of similar models, ML-800S2 and ML-800S3 Series, and report correction. LR 65928-35 1993-11-18 Alternate housing material and thickness shield, and report correction. LR 65928-27 1992-06-18 Include terminal block, Series ML-810. LR 65928-21 1990-07-26 Original Certification.
6592851	September 28, 1998	LR 65928-51 - Revised rating from 250V to 300V for Series ML-800, alternate button and terminal, addition of similar models, ML-800S2 and ML-800S3 Series, and report correction.
6592835	November 18, 1993	LR 65928-35 - Alternate housing material and thickness shield, and report correction.
6592827	June 18, 1992	LR 65928-27 - Include terminal block, Series ML-810.



Certificate: 1083851

Master Contract: 176070

Project: 80194072

Date Issued: 12/27/2023

6592821 July 26, 1990 LR 65928-21 - Original Certification.